



5513 Vine Street  
Cincinnati OH 45217  
Office (513) 242-2051  
Fax (513) 242-0816

Project:

Site Address:

General Contractor:

Other Useful Information:

**Minimum Information Required in Soils Report for Foundation Design**

- Allowable soil bearing capacity
- Allowable skin friction coefficient
- Allowable lateral bearing pressure for resistance to lateral loads and moments
- Depth to water table, if applicable
- Presence of collapsible soils

This information shall be included in a Geotech Report that is prepared and sealed by a Registered Professional Engineer. When requesting the report, it should be noted that drilled piers are the intended type of foundation for this structure, and that the soil be tested to a minimum depth of 10'-0". Any special design considerations and/or conditions should be included in the report. Signed and sealed foundation calculations cannot be provided without an appropriately signed and sealed Geotech Report.